



# CITY OF MANVEL

<http://www.cityofmanvel.com>

PO Box 187  
Manvel, Texas 77578

Phone: (281) 489-0630  
Fax: (281) 489-0634

---

**Mandatory Language for Monitoring/Reporting Violation  
Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)  
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The CITY OF MANVEL water system PWS ID 0200407 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This/These violation(s) occurred in the monitoring period(s) 01/01/2020-03/31/2020

We are taking the following actions to address this issue:

Hired a licensed operator to insure accurate and timely delivery of DLQOR to the City residents and the TCEQ. Placing notifications of this type on the Cities calendar as to receive notifications as a reminder to send and post information

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Ray Word at 281-734-4401

Posted /Delivered on: 8/24/2021

---

Certified by: Name (print): Ray Word  
Phone: 281-734-4401  
Signature: Ray Word

Title: Chief Plant Operator  
Date Signed: 8/23/2021